

ORIGINAL



0000163043

RECEIVED

2015 APR 28 AM 11:01
APRIL 22, 2015

ARIZONA CORPORATION COMMISSION
DOCKET CONTROL

ATTN: DOCKET CONTROL
enclosed find 13 original
~~AND~~ LEAK Fund Report From
EAGLETAIL WATER company
DOCKET NO. W-03936A-04-0840
DECISION NO. 67982

SUSAN E. HAAS
928-372-2236

Arizona Corporation Commission

DOCKETED

APR 28 2015

DOCKETED BY RC

EAGLETAIL WATER CO., LLC

P.O. Box 157
Tonopah, AZ 85354
928-372-2236

RECEIVED

2015 APR 28 A 11:01

April 22, 2015

AZ CORP COMMISSION
DOCKET CONTROL

Docket Control
Arizona Corporation Commission
1200 W. Washington St.
Phoenix, AZ 85007

Re: Docket No. W-03936A-04-0840
Decision No. 67982

As per item #20 line17 we are filing this quarterly report listing all revenue and disbursements from our Leak Fund. The above-mentioned Decision went into effect August 01, 2005.

Balance as of Jan 22	1297.53	
Revenue: Month of Jan	65.83	
Revenue: Month of Feb	55.83	
Revenue: Month of March	71.14	Disbursements
Interest earned	.04	
Balance as of April	\$1490.37	

We fixed (11) leaks this quarter:

01/31/15	541 st Ave. south of Airway	Repair damaged 4" main line
02/01/15	545 th Ave. Weutz meter	Repair leaking 6" main line saddle
02/01/15	545 th Ave. Henderson meter	Repair leaking 3/4" meter connector
02/07/15	539 th Ave. & Eagletail Rd.	Repair leaking chlorinator at yard
02/14/15	539 th Ave. & Eagletail Rd.	Repair leaking fire hydrant base
03/07/15	541 st Ave. @ dog farm	Cap off leaking unused 2" meter line
03/07/15	537 th Ave. & irrigation canal	Repair leaking 6" main line 90deg."L"
03/07/15	West of 541 st Ave. north of Airway	Cap off old 3/4" hot tap
03/07/15	East of 541 st Ave. south of Airway	Replace leaking 2" line w/air check
03/07/15	543 rd Ave. & Airway	Repair leaking 6" main line
03/07/15	539 th Ave & Eagletail Rd.	Replace nonworking 8" valve

If you have any questions regarding this report please call 928-372-2236 or contact us at the address above.

Respectfully,
Eagletail Water Co. LLC