

ORIGINAL



0000167695

RECEIVED

2016 JAN 26 A 10: 23

AZ CORP COMMISSION  
DOCKET CONTROL

January 21, 2015


Docket Control Center  
Arizona Corporation Commission  
1200 West Washington St  
Phoenix, AZ 85007

Arizona Corporation Commission

DOCKETED

JAN 26 2016

Docket E-02044A-98-0136



Dear Sir,

We are submitting the following information as required by the Arizona Corporation Commission Regulation 14-2-209 E, Meter Testing and Maintenance.

2015

Number of Meters tested	150
Size of meters	Class 100/200
Type of Meters	Form 2S and 12S

All meters tested were done on the initiative of the Cooperative and all meters tested were within the guidelines set.

If we can be of further assistance, please feel free to contact our office

Respectfully,  
Dixie Escalante REA  
Susan Davis/Consumer Accounts