

ORIGINAL

The Morenci Water & Electric (

401 Burro Alley  
P.O. Box 68  
Morenci, AZ 85540  
Telephone (928) 865-2229  
Facsimile (928) 865-5261



0000168910

March 7, 2016

RECEIVED  
AZ CORP COMMISSION  
DOCKET CONTROL

2016 MAR 10 PM 12 13

Arizona Corporation Commission  
Utilities Division  
1200 West Washington Street  
Phoenix, AZ 85007

Re: 2015 – Meter Testing and Maintenance Program  
Docket # E-00000-D-16-0057

Dear Staff:

The following are results from The Morenci Water & Electric Company 2015 meter testing program.

Total electric meters tested – 27 meters for the test program

Electric meters tested with error greater than or less than 3% - 0 meters for the test program

Total for maintenance electric meters – 78 meters for maintenance program

Electric meters tested with error greater than or less than 3% - 0 meters for the maintenance program

Customers requesting electric meter test – 1

Customers requesting water meter test – 0

Total water meters tested – 12

Total water meters maintenance - 162

Please let me know if you have any questions or comments.

Sincerely,

Ruel A. Rogers, Jr.  
Superintendent

WAG/wag  
XC: Brian Bozzo, ACC Staff

Arizona Corporation Commission

DOCKETED

MAR 10 2016

DOCKETED BY	
-------------	--