

ORIGINAL



1 Steve Wene, State Bar No. 019630
2 MOYES SELLERS & HENDRICKS LTD.
3 1850 N. Central Ave., Suite 1100
4 Phoenix, Arizona 85004
5 Telephone: 602-604-2141
6 e-mail: swene@lawms.com

RECEIVED

2016 MAR 31 P 3: 53

AZ CORP COMMISSION
DOCKET CONTROL

BEFORE THE ARIZONA CORPORATION COMMISSION


COMMISSIONERS

9 DOUG LITTLE, CHAIRMAN
10 BOB STUMP
11 BOB BURNS
12 TOM FORESE
13 ANDY TOBIN

Arizona Corporation Commission

DOCKETED

MAR 31 2016



14 IN THE MATTER OF THE APPLICATION
15 OF DRAGON WATER COMPANY, INC.
16 FOR AN INCREASE IN ITS RATES; AND

DOCKET NO. W-01917A-14-0312
NO. W-01917A-14-0313

17 IN THE MATTER OF THE APPLICATION
18 OF DRAGON WATER COMPANY, INC.
19 FOR AUTHORITY TO INCUR LONG-
20 TERM DEBT.

**NOTICE OF COMPLIANCE RE
FILING WATER LOSS REPORT**

21 Pursuant to Decision No. 75037, Dragoon Water Company, Inc. hereby files its
22 water loss report set forth in Attachment 1.

23 RESPECTFULLY SUBMITTED this 31st day of March, 2016.

24 **MOYES SELLERS & HENDRICKS LTD.**

25
26
27 _____
28 Steve Wene

1 Original and 13 copies of the foregoing
2 filed this 31st day of March, 2016 with:

3 Docket Control
4 Arizona Corporation Commission
5 1200 West Washington Street
6 Phoenix, Arizona 85007

7 
8
9

10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

ATTACHMENT 1

Monthly Water Loss Report

Water Company:

For the Month of:

Water Pumped this month: gallons
Water Purchased this month: gallons

A: Total Water Produced = 612,000 gallons

Total Water Sold = 586,000 gallons

B: Difference: (Produced - Sold) = 26,000 gallons

% Difference (B/A) = Total Water Loss: 4%

Gallons of Water Accounted For:

Breaks (Estimated Total):	<input type="text"/>	gallons
Hydrant or DVA Flushing (Estimated):	<input type="text"/>	gallons
Storage Tank Overflow:	<input type="text"/>	gallons
Other (Estimated):	<input type="text"/>	gallons
Wastewater Treatment Plant Use:	<input type="text"/>	gallons
Fire Department Use:	<input type="text"/>	gallons
Adjustment + / -:	<input type="text"/>	gallons

C: Total Gallons Accounted For = 0 gallons

Loss: Unaccounted-for Water: (B-C) = 26,000 gallons

% Loss (B-C)/A = Unaccounted for Loss: 4%

Monthly Water Loss Report

Water Company: Dragoon Water Company

For the Month of: February-16

Water Pumped this month: 514,000 gallons
 Water Purchased this month: gallons

A: Total Water Produced = 514,000 gallons

Total Water Sold = 396,000 gallons

B: Difference: (Produced - Sold) = 118,000 gallons

% Difference (B/A) = Total Water Loss: 23%

Gallons of Water Accounted For:

Breaks (Estimated Total):		gallons
Hydrant or DVA Flushing (Estimated):		gallons
Storage Tank Overflow:		gallons
Other (Estimated):		gallons
Wastewater Treatment Plant Use:		gallons
Fire Department Use:		gallons
Adjustment + / -:		gallons

C: Total Gallons Accounted For = 0 gallons

Loss: Unaccounted-for Water: (B-C) = 118,000 gallons

% Loss (B-C)/A = Unaccounted for Loss: 23%

Possible leak - will monitor.

Monthly Water Loss Report

Water Company: Dragoon Water Company

For the Month of: March-16

Water Pumped this month: 727,000 gallons
Water Purchased this month: gallons

A: Total Water Produced = 727,000 gallons

Total Water Sold = 588,000 gallons

B: Difference: (Produced - Sold) = 139,000 gallons

% Difference (B/A) = Total Water Loss: 19%

Gallons of Water Accounted For:

Breaks (Estimated Total):	88,000	gallons
Hydrant or DVA Flushing (Estimated):		gallons
Storage Tank Overflow:		gallons
Other (Estimated):		gallons
Wastewater Treatment Plant Use:		gallons
Fire Department Use:		gallons
Adjustment + / -:		gallons

C: Total Gallons Accounted For = 88,000 gallons

Loss: Unaccounted-for Water: (B-C) = 51,000 gallons

% Loss (B-C)/A = Unaccounted for Loss: 7%

February 18th located a line break on the high pressure line. Line size 3", 3 hour duration to repair, Approximately 88,000 gallons lost.