

ORIGINAL

NEW APPLICATION



0000173022

Company Name: Oak Creek Water Co. No. 1

CROSS-CONNECTION OR BACKFLOW TARIFF

PURPOSE: W-01392A-16-0294

The purpose of this tariff is to protect Oak Creek Water Co. No. 1 ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is not applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

****FOR OFFICIAL USE ONLY**** Arizona Corporation Commission

DOCKETED

AUG 25 2016

Effective Date: _____

DOCKETED BY	<i>MA</i>
-------------	-----------

RECEIVED
AZ CORP COMMISSION
DOCKET CONTROL
2016 AUG 25 P 12:02

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location
 - c. date(s) of test(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.


****FOR OFFICIAL USE ONLY****

Effective Date: _____

F A X

Oak Creek Water Co. No. 1

90 Oak Creek Blvd.
Sedona, AZ 86336
928 282-3404
Oakcreekwater.com



To: AL, ACC
Fax number: (602) 542-2129

From: Oak Creek Water Company
Fax number: 928 282-5558

Date: 8-24-16

Regarding: 9 PAGES/INC COVER

Phone number for follow-up:
928 282-3404

Comments:

SEE ATTACHED FOR

- 1) OUTAGE REPORT
- 2) CROSS CONNECTION TARIFF
- 3) CUSTOMER NOTIFICATION / AFFIDAVIT OF MAILING.

THANK YOU,

KRISTIN WAKEMAN
OAK CREEK WATER
928 282-3404 PH
928 282-5558 FAX