

ORIGINAL

Lake Verde Water

PO Box 2777 Camp Verde, AZ 86322
928-567-8592
Morgan.heritagesurvey@gmail.com



0000173239

Re:
AZ CORP COMMISSION
DOCKET CONTROL

2016 SEP 8 AM 10 35

September 7, 2016

ACC Docket Control
1200 W Washington Street
Phoenix, AZ 85007

Attached to this letter you will find the Arizona Department of Environmental Quality Certificate of approval to construct for Docket # W-01557A-15-0079 and ~~W-01557A-15-0080~~

Thank you


All the best

Brenda Mc Donald
Lake Verde Water Co.

Arizona Corporation Commission

DOCKETED

SEP 08 2016

DOCKETED BY 





**ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY
 CERTIFICATE OF APPROVAL TO CONSTRUCT
 WATER FACILITIES**

ADEQ File No: 20160137	LTF No: 64167
System Name: Lake Verde Water Co	System Number: 13-038
Project Owner: Lake Verde Water Co Inc	
Address: P O Box 2777, Campe Verde , AZ 86322	
Project Location: Camp Verde	County : Yavapai
Description: INSTALLATION OF A 20-GPM ARSENIC TREATMENT SYSTEM WITH METSORB HMRG MEDIA.	

Approval to construct the above-described facilities as represented in the approved documents on file with the Arizona Department of Environmental Quality is hereby given subject to provisions 1 through 1 continued on page 1 through 1

1. This project must be constructed in accordance with all applicable laws, including Title 49, Chapter 2, Article 9 of the Arizona Revised Statutes and Title 18, Chapter 5, Article 5 of the Arizona Administrative Code.
2. Upon completion of construction, the engineer shall fill out the Engineer's Certificate of Completion and forward it to the Central Regional Office located in Phoenix. If all requirements have been completed, that unit will issue a Certificate of Approval of Construction. R18-5-507(B), Ariz. Admin.Code. At the project owner's request, the Department may conduct the final inspection required pursuant to R18-5-507(B); such a request must be made in writing in accordance with the time requirements of R18-5-507(C), Ariz. Admin. Code.
3. This certificate will be void if construction has not started within one year after the Certificate of Approval to Construct is issued, there is a halt in construction of more than one year, or construction is not completed within three years of the approval date. Upon receipt of a written request for an extension of time, the Department may grant an extension of time; an extension of time must be in writing. R18-5-505(E), Ariz. Admin. Code.
4. Operation of a newly constructed facility shall not begin until a Certificate of Approval of Construction has been issued by the Department. R18-5-507(A), Ariz. Admin. Code.

Reviewed by: RDR

By: Fahmida Maula 8/26/16
 Fahmida Maula Date
 Water Quality Division

cc: File No: 20160137
 Regional Office: Central
 Owner: Lake Verde Water Co Inc
 County Health Department: Yavapai
 Engineer: Mills Engineering Llc
 Planning and Zoning/Az Corp. Commission
 Engineering Review Database - Etr021