

ORIGINAL



0000173649

1 Steve Wene, No. 019630
2 MOYES SELLERS & HENDRICKS LTD.
3 1850 N. Central Avenue, Suite 1100
4 Phoenix, Arizona 85004
5 (602)-604-2189
6 swene@law-msh.com
7 Attorneys for Truxton Canyon Water
8 Company, Inc.

RECEIVED
AZ CORP COMMISSION
DOCKET CONTROL

2016 SEP 29 PM 4: 29

BEFORE THE ARIZONA CORPORATION COMMISSION

COMMISSIONERS

9 DOUG LITTLE, CHAIRMAN
10 BOB STUMP
11 BOB BURNS
12 TOM FORESE
13 ANDY TOBIN

Arizona Corporation Commission

DOCKETED

SEP 29 2016

DOCKETED BY *YH*

14 IN THE MATTER OF THE APPLICATION
15 OF TRUXTON CANYON WATER
16 COMPANY, INC. FOR AUTHORITY TO
17 INCUR LONG-TERM DEBT.

DOCKET NO. W-02168A-15-0369

**STATUS UPDATE REGARDING
TREATMENT PLANT
INSTALLATION**

18
19 As requested, Truxton Canyon Water Company, Inc., (“Company” or “Truxton”)
20 hereby files its final approval of construction regarding construction of the water
21 treatment facility. Attachment 1. Construction of the treatment facility was finished on
22 July 15, 2016.
23

24 RESPECTFULLY SUBMITTED this 29th day of September, 2016.

25
26 **MOYES SELLERS & HENDRICKS**

27 *Steve Wene*

28 Steve Wene

1 Original and 13 copies
2 of the foregoing filed this 29th day
3 of September, 2016 with:

4 Docket Control
5 Arizona Corporation Commission
6 1200 West Washington Street
7 Phoenix, Arizona 85007

8 *Donnelly Herbst*
9 _____

10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

ATTACHMENT 1



Douglas A. Ducey
Governor

ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY



Misael Cabrera
Director

APPROVAL OF CONSTRUCTION

Project Description: CONSTRUCT 1-ARSENIC TREATMENT UTILIZING SEVERN-TRENT BAYOXIDE E33 ABSORPTION MEDIA TREATING 155 GPM & BLENDING/BYPASSING 345 GPM SUMMER TIME, TREATING 88 GPM & BLENDING/BYPASSING 162 GPM WINTER TIME.

Location: Kingman, AZ,

Project Owner: Truxton Canyon Water Company

Address: 7313 E Concho Drive, Kingman, AZ 86401

The Arizona Department of Environmental Quality (ADEQ) hereby issues an Approval of Construction for the above-described facility based on the following provisions of Arizona Administrative Code (A.A.C.) R18-5-507 et seq.


On July 7th, 2016, Robert Upton, P.E. certified that the project was built according to the as-built plans and specifications and ADEQ's Certificate of Approval to Construct.

On January 27th, 2016, ADEQ issued a Certificate of Approval to Construct for the referenced project.

This Approval of Construction authorizes the owner to begin operating the above-described facilities as represented in the approved plan on file with the ADEQ. Be advised that A.A.C. R18-4-203 requires the owner of a public water system to maintain and operate all water production, treatment and distribution facilities in accordance with ADEQ Safe Drinking Water Rules.

FM

PWS No.: 08-035
LTF No.: 64470


Fahmida Maula, PE

8/4/16
Date Approved

C: ADEQ File No.: 20160015
Mohave County Health Department
AZ Corporation Commission

Main Office
1110 West Washington Street • Phoenix, AZ 85007
(602) 771-2300

Southern Regional Office
400 West Congress Street • Suite 433 • Tucson, AZ 85701
(520) 628-6733

www.azdeq.gov
printed on recycled paper