

ORIGINAL
ORIGINAL

NEW APPLICATION



RECEIVED
AZ CORP COMMISSION
DOCKET CONTROL

2016 OCT 25 A 11:54


Ponderosa Utility Corporation
949 Osage
Flagstaff, AZ 86005

Arizona Corporation Commission
DOCKETED

OCT 25 2016

October 21, 2016

W-01717A-16-0385



Docket Control
Arizona Corporation Commission
1200 West Washington Street
Phoenix, Arizona 85007

Attached is an application by Ponderosa Utility Corporation for approval of a Cross-Connection Tariff. The purpose of this tariff is to protect Ponderosa Utility Corporations water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises.

Marshall S. Brown
Company Representative's Signature

Marshall T. Brown
Company Representative's Name

CROSS-CONNECTION OR BACKFLOW TARIFF**PURPOSE:**

The purpose of this tariff is to protect Ponderosa Utility Corporation's water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. Ponderosa Utility Corporation may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, Ponderosa Utility Corporation may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff
4. Ponderosa Utility Corporation shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, Ponderosa Utility Corporation or Commission Staff may suspend this requirement for a reasonable period of time.

****FOR OFFICIAL USE ONLY****

Effective Date: _____

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. Ponderosa Utility Corporation may require the customer to pay to have the backflow-prevention assembly tested as long as Ponderosa Utility Corporation does not require an unreasonable number of tests.
6. The customer shall provide Ponderosa Utility Corporation with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location
 - c. date(s) of test(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, Ponderosa Utility Corporation may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

****FOR OFFICIAL USE ONLY****

Effective Date: _____