

COPPER MARKET INC

PO Box 245
Bagdad, AZ 86321

William V. Taylor
Utilities Supervisor
Tel (928) 633-3111
E-mail btaylor2@



0000177809

ORIGINAL

March 1, 2017

RECEIVED

MAR 03 2017

Docket Control Center
Attention: Trish Meeter
1200 W. Washington
Phoenix, Arizona 85007

ARIZONA CORP COMMISSION
UTILITIES DIVISION - DIRECTOR'S OFFICE

Re: 2016 Gas Meter Testing and Maintenance Report

DOCKET NUMBER: ~~G-50DD-17-0025~~ DECISION: 0

9-0000DD-17-0025

METERS TESTED

<u>COMPANY</u>	<u>CUSTOMER</u>	<u>TOTAL</u>
<u>INITIATIVE</u>	<u>REQUESTS</u>	<u>METERS TESTED</u>
63	1	64

METERS TESTED OUTSIDE ALLOWANCE OF ±3%

<u>COMPANY</u>	<u>CUSTOMER</u>	<u>TOTAL</u>
<u>INITIATIVE</u>	<u>REQUESTS</u>	<u>METERS TESTED</u>
2	0	64

MAINTENANCE SUMMARY

Copper Market, INC. tested 2 meters that were outside the ± 3% allowance.

Sincerely,

William Taylor
Utilities Supervisor

RECEIVED
AZ CORP COMMISSION
DOCKET CONTROL
2017 MAR - 3 P 3: 21

Arizona Corporation Commission

DOCKETED

MAR 3 2017

DOCKETED BY
GP